


## KVALITETA ZRAKA U PROSTORU CASE STUDY



- Samo nekoliko stupnjeva razlike može umanjiti odnosno povećati produktivnost za 5%.

## EFIKASNOST





11:00  
CO2  
464 PPM  
TVOC  
29 PPB

11:00  
CO2  
5 PPM  
TVOC  
45 PPB

11:00  
CO2  
3 PPM  
TVOC  
45 PPB

11:00  
CO2  
15 PPM  
TVOC  
46 PPB



09:00



11:00  
CO2  
548 PPM  
TVOC  
32 PPB

11:00  
CO2  
546 PPM  
TVOC  
10 PPB

11:00  
CO2  
527 PPM  
TVOC  
12 PPB

11:00  
CO2  
525 PPM  
TVOC  
20 PPB



ODLIČNO  
DOBRO  
POTREBNO PROVJETRAVANJE  
HITNO PROVJETRAVANJE

09:15



11:00  
CO2  
579 PPM  
TVOC  
40 PPB

11:00  
CO2  
570 PPM  
TVOC  
24 PPB

11:00  
CO2  
543 PPM  
TVOC  
27 PPB

11:00  
CO2  
540 PPM  
TVOC  
30 PPB



09:30



11:00  
CO2  
636 PPM  
TVOC  
34 PPB

11:00  
CO2  
636 PPM  
TVOC  
22 PPB

11:00  
CO2  
615 PPM  
TVOC  
10 PPB

11:00  
CO2  
640 PPM  
TVOC  
3 PPB



09:45



11:00

CO2  
760 PPM

TVOC  
31 PPB

☀️ ■■■□□  
TVOC ■■■□□

11:00

CO2  
700 PPM

TVOC  
26 PPB

☀️ ■■■□□  
TVOC ■■■□□



11:00

CO2  
781 PPM

TVOC  
8 PPB

☀️ ■■■□□  
TVOC ■■■□□

11:00

CO2  
780 PPM

TVOC  
12 PPB

☀️ ■■■□□  
TVOC ■■■□□



10:00



11:00  
CO2  
944 PPM  
TVOC  
46 PPB

11:00  
CO2  
809 PPM  
TVOC  
52 PPB

11:00  
CO2  
988 PPM  
TVOC  
36 PPB

11:00  
CO2  
980 PPM  
TVOC  
40 PPB



10:15



11:00  
CO2  
1048 PPM  
TVOC  
65 PPB

11:00  
CO2  
879 PPM  
TVOC  
78 PPB

11:00  
CO2  
1010 PPM  
TVOC  
59 PPB

11:00  
CO2  
1088 PPM  
TVOC  
55 PPB

ODLIČNO  
DOBRO  
POTREBNO PROVJETRAVANJE  
HITNO PROVJETRAVANJE

10:30



11:00  
CO2  
1107 PPM  
TVOC  
74 PPB

11:00  
CO2  
929 PPM  
TVOC  
96 PPB

11:00  
CO2  
1123 PPM  
TVOC  
71 PPB

11:00  
CO2  
1115 PPM  
TVOC  
65 PPB

RADISSON COLLECTION  
OLD PILL, BELGRADE



10:45



11:00

CO2  
1158 PPM

TVOC  
82 PPB

☀️ ■■■■  
TVOC ■■■■

11:00

CO2  
952 PPM

TVOC  
101 PPB

☀️ ■■■■  
TVOC ■■■■



11:00

CO2  
1158 PPM

TVOC  
81 PPB

☀️ ■■■■  
TVOC ■■■■

11:00

CO2  
1145 PPM

TVOC  
75 PPB

☀️ ■■■■  
TVOC ■■■■



11:00



11:00  
CO2  
1167 PPM  
TVOC  
86 PPB

11:00  
CO2  
947 PPM  
TVOC  
107 PPB

11:00  
CO2  
1167 PPM  
TVOC  
89 PPB

11:00  
CO2  
1155 PPM  
TVOC  
85 PPB



11:15



11:00  
CO2  
947 PPM  
TVOC  
89 PPB

11:00  
CO2  
1173 PPM  
TVOC  
113 PPB

11:00  
CO2  
1168 PPM  
TVOC  
95 PPB

11:00  
CO2  
1158 PPM  
TVOC  
90 PPB



11:30



11:00  
CO2  
1174 PPM  
TVOC  
92 PPB

11:00  
CO2  
949 PPM  
TVOC  
114 PPB

11:00  
CO2  
1168 PPM  
TVOC  
100 PPB

11:00  
CO2  
1150 PPM  
TVOC  
105 PPB

RADISSON COLLECTION  
OLD MILL BELGRADE

ODLIČNO  
DOBRO  
POTREBNO PROVJETRAVANJE  
HITNO PROVJETRAVANJE

11:45



11:00

CO2  
1110 PPM

TVOC  
80 PPB

☀️ ■■■□□  
TVOC ■■■□□

11:00

CO2  
1097 PPM

TVOC  
95 PPB

☀️ ■■■□□  
TVOC ■■■□□

11:00

CO2  
946 PPM

TVOC  
93 PPB

☀️ ■■■□□  
TVOC ■■■□□

11:00

CO2  
967

TVOC  
90 PPB

☀️ ■■■□□  
TVOC ■■■□□



12:00



11:00  
CO2  
623 PPM  
TVOC  
39 PPB

11:00  
CO2  
612 PPM  
TVOC  
41 PPB

11:00  
CO2  
650 PPM  
TVOC  
44 PPB

11:00  
CO2  
645 PPM  
TVOC  
47 PPB



ODLIČNO  
DOBRO  
POTREBNO PROVJETRAVANJE  
HITNO PROVJETRAVANJE

12:15



11:00  
CO2  
912 PPM  
TVOC  
59 PPB

11:00  
CO2  
804 PPM  
TVOC  
66 PPB

11:00  
CO2  
800 PPM  
TVOC  
55 PPB

11:00  
CO2  
812 PPM  
TVOC  
52 PPB



12:30



11:00  
CO2  
1054 PPM  
TVOC  
65 PPB

11:00  
CO2  
1056 PPM  
TVOC  
63 PPB

11:00  
CO2  
1043 PPM  
TVOC  
59 PPB

11:00  
CO2  
1040 PPM  
TVOC  
55 PPB



12:45



11:00  
CO2  
1110 PPM  
TVOC  
68 PPB

11:00  
CO2  
1123 PPM  
TVOC  
61 PPB

11:00  
CO2  
1098 PPM  
TVOC  
64 PPB

11:00  
CO2  
1110 PPM  
TVOC  
64 PPB



13:00